

Notes:

Not Treated for Barium Removal

Post = Post Treatment

Post (#) refers to test results in a series of results.

All units in ppm (mg/L) unless other wise specified

Pre = Pre-Treatment



Ecolotron, Inc.
The Electrocoagulation Specialists

Location/ Parameter	Plastics		Paint		Refining		Waste Tank		Waste Tank		Waste Tank		Textile	
	PRE	POST	PRE	POST	PRE	POST	PRE	POST	PRE	POST	PRE	POST	PRE	POST
Aerobic B. (cfu/100ml)														
Aluminum								BRL	0.8172	0.8495				
APB (cfu/100ml)														
Barium							2356	1933	1973	1634				
BOD			2.4											
Boron														
BTEX Total					0.279	0.0894								
Calcium							1244	1117	1115	1091				
Chloride														
Chromium														
CO ₃														
COD					242	77							449	242
Copper														
Fluoride														
FOD														
HCO ₃														
Iron	7.4	0.075					33.86	BRL	0.2163	BRL				
Magnesium							134.1	90.1	124.1	127				
Manganese														
Nitrate														
Phosphate	6.3	0.45												
Potassium														
Si														
SRB (cfu/100ml)														
Strontium							682	658	665	655				
Sulfate														
TDS			720											
TPH c6-35			0.8		37.6	5.21					73.58	7.41		

--	--